SIEMENS

Data sheet

3RW3026-1BB14





SIRIUS soft starter S0 25 A, 11 kW/400 V, 40 °C 200-480 V AC, 110-230 V AC/DC Screw terminals

General technical data		
product brand name		SIRIUS
product designation		Soft starter
product feature		
 integrated bypass contact system 		Yes
thyristors		Yes
product function	_	
 intrinsic device protection 		No
 motor overload protection 		No
 evaluation of thermistor motor protection 		No
external reset		No
 adjustable current limitation 		No
inside-delta circuit		No
product component motor brake output		No
insulation voltage rated value	V	600
degree of pollution		3, acc. to IEC 60947-4-2
blocking voltage of the thyristor maximum	V	1 600
reference code according to EN 61346-2		Q
reference code according to DIN 40719 extended according to IEC 204-2 according to IEC 750		G
Power Electronics		
operational current		
• at 40 °C rated value	А	25
• at 50 °C rated value	А	23
• at 60 °C rated value	А	21
yielded mechanical performance for 3-phase motors		
• at 230 V		
- at standard circuit at 40 °C rated value	kW	5.5
• at 400 V		
— at standard circuit at 40 °C rated value	kW	11
yielded mechanical performance [hp] for 3-phase AC motor at 200/208 V at standard circuit at 50 °C rated value	hp	5
operating frequency rated value	Hz	50 60
relative negative tolerance of the operating frequency	%	-10
relative positive tolerance of the operating frequency	%	10
operating voltage at standard circuit rated value	V	200 480
relative negative tolerance of the operating voltage at standard circuit	%	-15
relative positive tolerance of the operating voltage at standard circuit	%	10
	%	10

		445
continuous operating current [% of le] at 40 °C	%	115
power loss [W] at operational current at 40 °C during operation typical	W	8
Control circuit/ Control		
type of voltage of the control supply voltage		AC/DC
control supply voltage frequency 1 rated value	Hz	50
control supply voltage frequency 2 rated value	Hz	60
relative negative tolerance of the control supply voltage frequency	%	-10
relative positive tolerance of the control supply voltage frequency	%	10
control supply voltage 1 at AC at 50 Hz	V	110 230
control supply voltage 1 at AC at 60 Hz	V	110 230
relative negative tolerance of the control supply voltage at AC at 50 Hz	%	-15
relative positive tolerance of the control supply voltage at AC at 50 Hz	%	10
relative negative tolerance of the control supply voltage at AC at 60 Hz	%	-15
relative positive tolerance of the control supply voltage at AC at 60 Hz	%	10
control supply voltage 1 at DC	V	110 230
relative negative tolerance of the control supply voltage at DC	%	-15
relative positive tolerance of the control supply voltage at DC	%	10
display version for fault signal		red
Mechanical data		
size of engine control device		SO
width	mm	45
height	mm	125
depth	mm	150
fastening method		screw and snap-on mounting
mounting position		With vertical mounting surface +/-10° rotatable, with vertical mounting surface +/- 10° tiltable to the front and back
required spacing with side-by-side mounting		
• upwards	mm	60
at the side	mm	15
downwards	mm	40
wire length maximum	m	300
number of poles for main current circuit		3
Connections/ Terminals		
type of electrical connection		
 for main current circuit 		screw-type terminals
 for auxiliary and control circuit 		screw-type terminals
number of NC contacts for auxiliary contacts		0
number of NO contacts for auxiliary contacts		1
number of CO contacts for auxiliary contacts		0
type of connectable conductor cross-sections for main contacts for box terminal using the front clamping point		
• solid		2x (1 2.5 mm²), 2x (2.5 6 mm²)
 finely stranded with core end processing 		2x (1 2.5 mm²), 2x (2.5 6 mm²)
type of connectable conductor cross-sections for AWG cables for main contacts for box terminal		
 using the front clamping point 		1x 8, 2x (16 10)
type of connectable conductor cross-sections for auxiliary contacts		
• solid		2x (0.5 2.5 mm²)
 finely stranded with core end processing 		2x (0.5 1.5 mm²)
type of connectable conductor cross-sections for AWG cables		
 for auxiliary contacts 		2x (20 14)
for auxiliary contacts finely stranded with core end processing		2x (20 16)
Ambient conditions		

				5 000		
installation altitude at heig	giit above sea level		m	5 000		
 environmental category during transport acco 	ording to IEC 60721			2K2 2C1 2S1	2M2 (max. fall height 0.3	3 m)
during transport accord during storage accord	8			1K6 (only occas	sional condensation), 1C	2 (no salt mist), 1S2
• during operation according to IEC 60721			3K6 (no formati	get inside the devices), on of ice, no condensation	on), 3C3 (no salt mist	
ambient temperature				552 (Sanu musi	not get into the devices), 51010
 during operation 			°C	-25 +60		
during storage		°C	-40 +80			
derating temperature		°C	40			
protection class IP on the	front according to I	EC 60529		IP20		
touch protection on the fre	ont according to IEC	60529		finger-safe, for	vertical contact from the	front
nvironmental footprint						
Global Warming Potential [C	CO2 eq] total		kg	137		
Global Warming Potential [C	Potential [CO2 eq] during manufacturing		kg	11		
global warming potential [Co	O2 eq] during sales		kg	0.151		
Global Warming Potential [C	CO2 eq] during operat	ion	kg	128		
Global Warming Potential [C	CO2 eq] after end of li	fe	kg	-2.27		
L/CSA ratings						
yielded mechanical perfor • at 220/230 V	rmance [hp] for 3-ph	ase AC motor				
- at standard circi	uit at 50 °C rated valu	e	hp	5		
• at 460/480 V						
— at standard circl	uit at 50 °C rated valu	e	hp	15		
contact rating of auxiliary	contacts according	to UL		B300 / R300		
	UK CA	CE EG-Konf.		<u>Confirmation</u>	(U)	EAC
	UK CA				U	EAC
EMV	UK CA	EG-Konf.			UL.	ERIC
EMV RCM	UK CA		s oth		Confirmation	ERC Environment
EMV EMV Environment	CA	Test Certificates	s oth	er	Confirmation	Environment
RCM Environment	CA	Test Certificates	s oth	er	Confirmation	
Environment Siemens EcoTech	KC Environmental Con-	Test Certificates	s oth	er	Confirmation	<section-header></section-header>
Environment Siemens EcoTech	KC Environmental Con- firmations	Test Certificates	s oth	er	Confirmation	ERC Environment
Environment Siemens EcoTech	KC Environmental Con- firmations	Test Certificates	s oth	er	Confirmation	
Environment Siemens EcoTech E Simulation Tool for Soft S https://support.industry.siem Information on the packag	KC Environmental Con- firmations	Test Certificates	s oth	er	Confirmation	
Environment Siemens EcoTech Environment EcoTech EcoT	KC Environmental Con- firmations Starters (STS) nens.com/cs/ww/en/vi ging nens.com/cs/ww/en/vi	Test Certificates Type Test Certi ates/Test Repo	s oth	er	Confirmation	
Environment Siemens	KC KC Environmental Con- firmations	Test Certificates Type Test Certi ates/Test Repo	s oth	er	Confirmation	
Environment Siemens EcoTech Environment Siemens EcoTech EcoTech EcoTech Environment EcoTech	KC Environmental Con- firmations Environmental Con- firmations Environmental Con- firmations Environmental Con- firmations	Test Certificates <u>Type Test Certi</u> <u>ates/Test Repo</u> <u>ates/Test Repo</u> <u>ew/101494917</u> <u>ew/109813875</u> <u>Brochures,)</u>	s oth fic- I ort	er <u>Miscellaneous</u>	Confirmation	
Environment Siemens EcoTech Environment Siemens EcoTech EcoTech EcoTech Environment EcoTech EcoTech Environment EcoTech EcoTe	KC Environmental Con- firmations Environmental Con- firmations Environmental Con- firmations Environmental Con- firmations Environmental Con- firmations Environmental Con- firmations	Test Certificates <u>Type Test Certi</u> <u>ates/Test Repr</u> <u>ew/101494917</u> <u>ew/109813875</u> Brochures,)	s other	er Miscellaneous		
Environment Environment Siemens EcoTech Urther information Simulation Tool for Soft S https://support.industry.siem Information on the packag https://support.industry.siem Information- and Downloa https://www.siemens.com/ic	KC Environmental Con- firmations	Test Certificates <u>Type Test Certi</u> <u>ates/Test Repo</u> <u>ates/Test Repo}</u>	s other	er Miscellaneous		





last modified:

11/9/2024 🖸